

Property Transfer Well(s) and Pressure System(s) Inspection
Form 3300-221 (R 10/14)

Notice: Pursuant to ch. 280, Wis. Stats., and ch. NR 812, Wis. Adm. Code, this form shall be used to document any well and pressure system inspection conducted as part of a property transfer. Inspections are voluntary, and well owners are not required to bring systems into compliance as a result of the inspection. Inspectors must provide the completed form to the requester of the inspection. Do not send forms to DNR.

Contact Information

Inspection Requested By		Telephone Number	
Mailing Address	City	State	ZIP Code
Owner's Name		Telephone Number	
Mailing Address	City	State	ZIP Code

Property Location

County of Water System Location	Grid or Street Address or Road Name and Number (if available)	City	ZIP Code
Township	Gov't Lot # $\frac{1}{4}$ of the $\frac{1}{4}$	Section	Town
		Range E/W	Unique Well Number
		N	

Known Noncomplying Features

Identified noncomplying features are noted below with a check mark.

- | | |
|--|--|
| 1. ☐ Unused Well Should be Filled and Sealed | 14. ☐ Hand Pump |
| 2. ☐ Stovepipe or Thin-Walled Casing | 15. ☐ Offset Pump or Piping Height < 12" Above Floor |
| 3. ☐ Dug Well | 16. ☐ Yard Hydrant |
| 4. ☐ Unprotected Buried Suction Line | 17. ☐ Materials for Pump and Supply Piping |
| 5. ☐ Alcove (Subsurface Pumproom) or Pit | 18. ☐ Flowing Well Installation |
| 6. ☐ Non-Walkout Basement or Below-Grade Crawl Space Well | 19. ☐ Check Valve Location |
| 7. ☐ Poor Casing Condition (Badly Corroded or Cracked) | 20. ☐ Well Cap or Seal |
| 8. ☐ Contaminant Source less than minimum separation distance from well: _____ | 21. ☐ Casing Height |
| 9. ☐ Well in Floodway or Flood Fringe | 22. ☐ Electrical Wires Not Properly Enclosed in Conduit |
| 10. ☐ Well at Risk from Localized Flooding | 23. ☐ Sample Faucet is Missing or Incorrect |
| 11. ☐ Cross-Connection | 24. ☐ Casing less than 6" in diameter for a well in limestone, dolomite, shale, quartz or granite |
| 12. ☐ Driven Point Well (installed after 1-31-1991) without construction report | 25. ☐ Health/Safety Hazard |
| 13. ☐ Nonpressure Conduit | |

Comments

- | | |
|--|--|
| ☐ Pre-1991 Driven Point Pipe Depth < 25 feet | ☐ Inaccessible or Difficult Location for Future Well Work |
| ☐ Well Construction Report Not on File or Unlocatable | ☐ Inaccessible or Difficult Location for Future Pump Work |
| ☐ Well Located in Special Well Casing Depth Area | ☐ Non-Vermin-Proof Well Cap or Well Seal |
| ☐ Pre-1979 Two-Wire Submersible Pump | ☐ Other: |
| ☐ Evidence of Some Corrosion on Well Casing Pipe | |

Based on my personal inspection of the real property, the well(s) and pressure system(s): ☐ **Complies** with Wis. Adm. Code.
☐ **Does not comply**

- ☐ More comprehensive or additional research is needed regarding:
- ☐ an unused well ☐ floodways/floodplains ☐ contaminant sources ☐ other:

This form lists the visible conditions of the well(s) and pressure system(s) on the property at the time of inspection and does not imply or give any guarantee.

Signature of Licensed Water Well Driller or Pump Installer	Individual License #	Date	Telephone Number
<i>Luke Ladwig</i>			